



CERTIFICATE

The company

PEXTUBE

Fábrica de Tubos
Plástico-Metálicos, S.A.
3750-753 TRAVASSÔ-ÁGUEDA
PORTUGAL

hereby receives the confirmation that the product/s

Plastic piping systems for warm water floor heating systems and radiator connecting

of the type


PE-Xb

conforms to

DIN 4726:2000-01
DIN EN ISO 15875-1:2004-03
DIN EN ISO 15875-2:2004-03
DIN EN ISO 15875-3:2004-03
DIN EN ISO 15875-5:2004-03

Certification scheme plastic piping systems for warm water floor heating systems and radiator connecting

and is granted the licence to use the mark



in conjunction with the Registration No. below.

Registration No.: 3V284 PE-Xb

The validity of certificate is bound to the verification of the semi-annual surveillance test.

See annex for further information.

DIN CERTCO Gesellschaft für
Konformitätsbewertung mbH
Alboinstraße 56, 12103 Berlin



2005-09-26

S. Scholz
Dipl.-Ing. Dipl.-Wf.-Ing. Sören Scholz
- Acting Head of Certification Body -

Annex

to the Certificate with Registration No. 3V284 PE-Xb, dated 2005-09-26

Technical data

Dimensions: 12, 16, 17, 20 x 2 mm; 15 x 2,5 mm, 16 x 2,2 mm

Fittings: metal clamping ring fittings-: 12, 16, 17, 20 x 2 mm; 15 x 2,5 mm, 16 x 2,2 mm

Application class: 5, operating pressure 10 bar: 12 x 2 mm, 15 x 2,5 mm, 16 x 2,2 mm

Application class: 5, operating pressure 8 bar: 16 x 2 mm, 17 x 2mm

Application class: 5, operating pressure 6 bar: 20 x 2 mm

Testing laboratory / Inspection body

Universität Stuttgart
- IKE - Lehrstuhl für Heiz-
und Raumluftechnik
Pfaffenwaldring 35
70569 Stuttgart

Test report(s)

KL.05.P.152 dated 2005-08-24